



February 28, 2020

Re: **20-IFB-PW232 Mechanical Bar Screen Replacement**

Dear Respondent(s):

This Addendum forms a part of the contract documents and **modifies** the original ITB documents as noted below:

- Question from Duperon: In reviewing Sierra Vista WWTP AZ, the bid docs state 1.75" clear opening on the bar screen. We typically do not offer a 1.75" opening (we can, however it will require a bit of additional cost to achieve). Our original proposal included 1.5" opening, which is ideal, will provide better capture for the site & the hydraulics look good. Can you please submit an RFI on our behalf to reduce the opening to 1.5"?

ANSWER: The 1.5 opening is acceptable per the plant personnel and design engineer.

Except as provided herein, all terms and conditions in the bid referenced above remain unchanged and in full force and effect. Failure to return a signed copy of this addendum could render your bid non-responsive.

#### ACKNOWLEDGEMENT OF ADDENDUM NO. 2

The undersigned proposer acknowledges receipt of this addendum by returning one (1) copy of this form with the bid package to the Procurement Division, City of Sierra Vista, 1011 North Coronado Drive, Sierra Vista, Arizona 85635 by the proposal due date and time, **March 10, 2020 before 2:00 P.M. ARIZONA LOCAL TIME.**

This is to acknowledge receipt of Addendum No. 2, \_\_\_\_\_ day of \_\_\_\_\_, 2020.

\_\_\_\_\_  
Name of Business

\_\_\_\_\_  
Signature of Authorized Representative/Title

A handwritten signature in blue ink, appearing to be "LJ", is written over a horizontal line.

**Linda Jones**  
**Interim Chief Procurement Officer**